

SOLDIER CANYON WATER TREATMENT AUTHORITY

(East Larimer County Water District; Fort Collins/Loveland Water District; North Weld County Water District)

WATER QUALITY REPORT

2ND QUARTER 2024

ANALYSIS PARAMETER <small>Monitored at SCFP (not a certified lab)</small>	Report	PLANT INFLUENT			PLANT EFFLUENT			MCL *SMCL
	Values	MIN	MAX	AVG	MIN	MAX	AVG	
ALKALINITY	mg/l	22.0	47.0	30.5	37.0	43.0	40.5	N/A
ALUMINUM	mg/l	N/A	N/A	N/A	0.040	0.055	0.049	*0.05 - 0.2
CALCIUM HARDNESS	mg/l	13.0	28.0	24.0	18.0	28.0	24.8	N/A
CHLORINE	mg/l	N/A	N/A	N/A	1.23	1.42	1.34	4.0 MRDL
CHLORITE	mg/l	N/A	N/A	N/A	0.23	0.74	0.43	1.0
CHLORINE DIOXIDE	mg/l	N/A	N/A	N/A	0.00	0.08	0.03	0.8
CONDUCTIVITY	µs/cm	36.6	86.4	72.1	99.2	133.8	115.4	N/A
DISSOLVED OXYGEN	mg/l	7.6	12.7	10.2	N/A	N/A	N/A	N/A
FLUORIDE	mg/l	0.11	0.28	0.18	0.62	0.81	0.68	4.0/*2.0
HARDNESS (TOTAL)	mg/l	14.0	49.0	31.4	24.0	35.0	30.9	N/A
IRON	mg/l	0.03	0.22	0.10	0.00	0.01	0.01	*0.3
MANGANESE	mg/l	0.014	0.049	0.024	0.001	0.015	0.005	*0.05
pH	VALUE	6.26	8.55	7.40	7.64	8.64	8.33	*6.5-8.5
TEMPERATURE	°C	4.7	16.6	10.8	5.3	13.6	9.1	N/A
TRUE COLOR	APHA	3.0	43.0	16.9	0.0	1.0	0.0	*15.0
TURBIDITY	NTU	0.79	39.98	2.98	0.013	0.067	0.017	**<0.3 TT

<u>INORGANIC CONTAMINANTS ANALYSES (SGS) - (EFFLUENT ENTRY POINT AT SCFP)</u>			RESULTS	DATE	MCL
ANTIMONY	mg/l		<0.00040	1/11/2023	0.006
ARSENIC	mg/l		<0.0020	1/11/2023	0.010
BARIUM	mg/l		0.020	1/11/2023	2.000
BERYLLIUM	mg/l		<0.00030	1/11/2023	0.004
CADMIUM	mg/l		<0.00015	1/11/2023	0.005
CHROMIUM	mg/l		<0.0020	1/11/2023	0.1
FLUORIDE	mg/l		0.60	1/11/2023	4.0
MERCURY	mg/l		<0.00010	1/11/2023	0.002
NICKEL	mg/l		<0.0020	1/11/2023	N/A
SELENIUM	mg/l		<0.00070	1/11/2023	0.050
SODIUM	mg/l		8.6	1/11/2023	N/A
THALLIUM	mg/l		<0.00020	1/11/2023	0.002

<u>NITRATE AND/OR NITRITE AS NITROGEN (SGS) - (EFFLUENT ENTRY POINT AT SCFP)</u>			RESULTS	DATE	MCL
NITRATE	mg/l		<0.0040	1/11/2023	10.000
NITRITE	mg/l		<0.010	1/11/2023	1.000

TOTAL ORGANIC CARBON (CA) - (SCFP INFLUENT AND CF EFFLUENT)

			INFLUENT	EFFLUENT	TT RATIO	DATE	MCL - **TT
TOTAL ORGANIC CARBON - TOC	mg/L		3.5	2.2	1.06	4/10/2024	RAA - ≥1.0
			4.3	2.2	1.09	5/7/2024	RAA - ≥1.0
			4.0	2.2	1.29	5/7/2024	RAA - ≥1.1
			6.0	2.2	1.41	6/12/2024	
			4.2	2.2	1.06	6/12/2024	

ALKALINITY (CA) - (SCFP INFLUENT)

			INFLUENT	DATE	MCL
ALKALINITY (CA) - (SCFP INFLUENT)	mg/l		28.5	4/10/2024	N/A
			27.9	5/7/2024	N/A
			30.0	5/7/2024	N/A
			20.1	6/12/2024	
			26.6	6/12/2024	

RADIONUCLIDE ANALYSES (SGS) - (EFFLUENT ENTRY POINT AT SCFP)

			RESULTS	DATE	MCL
GROSS ALPHA	pCi/L		ND	9/8/2021	15
URANIUM	ppb		<0.00020	9/8/2021	30
RADIUM 226 + 228	pCi/L		ND	9/8/2021	5
GROSS BETA	pCi/L		ND	9/8/2021	50

ORGANIC CHEMICAL ANALYSES - VOC's (SGS) - (EFFLUENT ENTRY POINT AT SCFP)

			RESULTS	DATE	MCL
1,1,1-TRICHLOROETHANE	µg/L		ND	1/11/2023	200
1,1,2-TRICHLOROETHANE	µg/L		ND	1/11/2023	5
1,1-DICHLOROETHYLENE	µg/L		ND	1/11/2023	7
1,2,4-TRICHLOROBENZENE	µg/L		ND	1/11/2023	70
1,2-DICHLOROETHANE	µg/L		ND	1/11/2023	5
1,2-DICHLOROPROPANE	µg/L		ND	1/11/2023	5
BENZENE	µg/L		ND	1/11/2023	5
CARBON TETRACHLORIDE	µg/L		ND	1/11/2023	5
CHLOROBENZENE	µg/L		ND	1/11/2023	100
cis-1,2-DICHLOROETHYLENE	µg/L		ND	1/11/2023	70
DICHLOROMETHANE	µg/L		ND	1/11/2023	5
ETHYLBENZENE	µg/L		ND	1/11/2023	700
o-DICHLOROENZENE	µg/L		ND	1/11/2023	600
para-DICHLOROENZENE	µg/L		ND	1/11/2023	75
STYRENE	µg/L		ND	1/11/2023	100
TETRACHLOROETHYLENE	µg/L		ND	1/11/2023	5
TOLUENE	µg/L		ND	1/11/2023	1000
trans-1,2-DICHLOROETHYLENE	µg/L		ND	1/11/2023	100
TRICHLOROETHYLENE	µg/L		ND	1/11/2023	5
VINYL CHLORIDE	µg/L		ND	1/11/2023	2
XYLENES (total)	µg/L		ND	1/11/2023	10000

ORGANIC CHEMICAL ANALYSES - SOC's (SGS)(CA) - (EFFLUENT ENTRY POINT AT SCFP)			RESULTS	DATE	MCL
1,2-DIBROMO-3-CHLOROPROPANE	µg/L		ND	1/11/2023	0.2
2,4-D	µg/L		ND	5/3/2023	70
2,4,5-TP	µg/L		ND	5/3/2023	50
ALACHLOR (LASSO)	µg/L		ND	1/11/2023	2
ALDICARB	µg/L		ND	1/11/2023	N/A
ALDICARB SULFONE	µg/L		ND	1/11/2023	N/A
ALDICARB SULFOXIDE	µg/L		ND	1/11/2023	N/A
ATRAZINE	µg/L		ND	1/11/2023	3
BENZO(a)PYRENE	µg/L		ND	1/11/2023	0.2
BHC-GAMMA/LINDANE	µg/L		ND	6/28/2023	0.2
CARBOFURAN	µg/L		ND	1/11/2023	40
CHLORDANE	µg/L		ND	1/11/2023	2
DALAPON	µg/L		ND	5/3/2023	200
DINOSEB	µg/L		ND	5/3/2023	7
DIQUAT	µg/L		ND	1/11/2023	20
DI(2-ethylhexyl)ADIPATE	µg/L		ND	1/11/2023	400
DI(2-ethylhexyl)PHTHALATE	µg/L		ND	5/3/2023	6
ENDOTHALL	µg/L		ND	1/11/2023	100
ENDRIN	µg/L		ND	1/11/2023	2
ETHYLENE DIBROMIDE	µg/L		ND	1/11/2023	0.05
HEPTACHLOR	µg/L		ND	1/11/2023	0.4
HEPTACHLOR EPOXIDE	µg/L		ND	1/11/2023	0.2
HEXACHLOROBENZENE	µg/L		ND	1/11/2023	1
HEXACHLOROCYCLOPENTADIENE	µg/L		ND	1/11/2023	50
METHOXYCHLOR	µg/L		ND	1/11/2023	40
OXAMYL	µg/L		ND	1/11/2023	200
PENTACHLOROPHENOL	µg/L		ND	5/3/2023	1
PICLORAM	µg/L		ND	5/3/2023	500
POLYCHLORINATED BIPHENYLS	µg/L		ND	1/11/2023	0.5
SIMAZINE	µg/L		ND	1/11/2023	4
TOXAPHENE	µg/L		ND	1/11/2023	3

POLYFLUOROALKYL SUBSTANCES (PFAS)(CA)			EPA PROPOSED MCL/HI			
			RESULTS	HI CALC.	DATE	MCL/HI
PFOA - Perfluorooctanoic	ng/L		ND	NA	6/12/2024	4.0 ng/L
PFOS - Perfluorooctanesulfonic acid	ng/L		ND	NA	6/12/2024	4.0 ng/L
PFNA - Perfluorononanoic acid	ng/L		ND	0	6/12/2024	10 ng/L-HI
PFHxS - Perfluorohexanesulfonic acid	ng/L		ND	0	6/12/2024	10 ng/L-HI
PFBS - Perfluorobutanesulfonic acid	ng/L		0.00086	0	6/12/2024	HI
HFPO-DA (GenX)	ng/L		ND	0	6/12/2024	10 ng/L-HI
HAZARD INDEX TOTAL	ng/L			0	6/12/2024	1.0 HI MCL

For more information on PFAS, please visit the EPA website at:
<https://www.epa.gov/sdwa/and-polyfluoroalkyl-substances-pfas>

DISTRIBUTION SYSTEMS SAMPLES

CHLORINE (Districts Measure)

		TOTAL SAMPLES	MIN	MAX	AVG	DATE	MRDL
EAST LARIMER COUNTY WATER DISTRICT	mg/L	25	0.35	0.97	0.69	Apr-24	4.0
EAST LARIMER COUNTY WATER DISTRICT	mg/L	25	0.56	1.04	0.86	May-24	4.0
EAST LARIMER COUNTY WATER DISTRICT	mg/L	25	0.54	1.17	0.90	Jun-24	4.0
<hr/>							
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	70	0.33	1.35	0.76	Apr-24	4.0
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	70	0.50	1.24	0.84	May-24	4.0
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	70	0.59	1.38	0.91	Jun-24	4.0
<hr/>							
NORTH WELD COUNTY WATER DISTRICT	mg/L	18	0.50	1.16	0.88	Apr-24	4.0
NORTH WELD COUNTY WATER DISTRICT	mg/L	18	0.56	1.12	0.90	May-24	4.0
NORTH WELD COUNTY WATER DISTRICT	mg/L	18	0.32	1.11	0.82	Jun-24	4.0

TOTAL COLIFORMS (MMS/WCL)

		TOTAL SAMPLES	# POSITIVE	# NEGATIVE	DATE	MCL **TT LEVEL 1 or 2
EAST LARIMER COUNTY WATER DISTRICT		25	0	25	Apr-24	NO/NO
EAST LARIMER COUNTY WATER DISTRICT		25	0	25	May-24	NO/NO
EAST LARIMER COUNTY WATER DISTRICT		25	0	25	Jun-24	NO/NO
<hr/>						
FT COLLINS/LOVELAND WATER DISTRICT		70	0	70	Apr-24	NO/NO
FT COLLINS/LOVELAND WATER DISTRICT		70	0	70	May-24	NO/NO
FT COLLINS/LOVELAND WATER DISTRICT		70	0	70	Jun-24	NO/NO
<hr/>						
NORTH WELD COUNTY WATER DISTRICT		18	0	18	Apr-24	NO/NO
NORTH WELD COUNTY WATER DISTRICT		18	0	18	May-24	NO/NO
NORTH WELD COUNTY WATER DISTRICT		18	0	18	Jun-24	NO/NO

DISTRIBUTION SYSTEMS SAMPLES - CONTINUED

<u>TOTAL TRIHALOMETHANES AND HALOACETIC ACIDS</u>		TTHM RESULTS	MCL (LRAA)	HAA RESULTS	MCL (LRAA)	DATE
<u>EAST LARIMER COUNTY WATER DISTRICT (SGS)</u>						
SAMPLE SITE - DBP001	µg/L	43.3	80	33.6	60	4/3/2024
SAMPLE SITE - DBP002	µg/L	76.3	80	27.6	60	4/3/2024
SAMPLE SITE - DBP003	µg/L	37.9	80	37.8	60	4/3/2024
SAMPLE SITE - DBP004	µg/L	62.8	80	28.5	60	4/3/2024

<u>FORT COLLINS/LOVELAND WATER DISTRICT (CA)</u>						
SAMPLE SITE - DBP001	µg/L	48.2	80	24.7	60	4/4/2024
SAMPLE SITE - DBP002	µg/L	45.6	80	35.6	60	4/4/2024
SAMPLE SITE - DBP003	µg/L	37.7	80	27.7	60	4/4/2024
SAMPLE SITE - DBP004	µg/L	33.2	80	28.0	60	4/4/2024
SAMPLE SITE - DBP005	µg/L	33.6	80	26.8	60	4/4/2024
SAMPLE SITE - DBP006	µg/L	48.2	80	27.9	60	4/4/2024
SAMPLE SITE - DBP007	µg/L	38.5	80	27.5	60	4/4/2024
SAMPLE SITE - DBP008	µg/L	39.5	80	28.4	60	4/4/2024

<u>NORTH WELD COUNTY WATER DISTRICT (WCL)</u>						
SAMPLE SITE - DBP001	µg/L	51.15	80	29.20	60	4/9/2024
SAMPLE SITE - DBP002	µg/L	30.10	80	35.50	60	4/9/2024
SAMPLE SITE - DBP003	µg/L	35.56	80	37.60	60	4/9/2024
SAMPLE SITE - DBP004	µg/L	31.59	80	35.70	60	4/9/2024

<u>CHLORITE</u>		1ST RES	AVG RES	MAX RES	DATE	MCL
FROM DISTRIBUTION SYSTEM(S)	mg/L	0.25	0.23	0.22	4/10/2024	1.0

<u>LEAD AND COPPER</u>		90TH PERCENTILE mg/L	DATE	90th% ACTION LEVEL mg/L
<u>EAST LARIMER COUNTY WATER DISTRICT (AL)</u>		30 SAMPLES COLLECTED		
LEAD	mg/L	0.004	Jun-Jul-2022	0.015
COPPER	mg/L	0.19	Jun-Jul-2022	1.3

<u>FORT COLLINS LOVELAND WATER DISTRICT (CA)</u>		60 SAMPLES COLLECTED		
LEAD	mg/L	0.003	JUN-JUL 2023	0.015
COPPER	mg/L	0.154	JUN-JUL 2023	1.3

<u>NORTH WELD COUNTY WATER DISTRICT (WCL)</u>		30 SAMPLES COLLECTED		
LEAD	mg/L	0.00279	Jun-21	0.015
COPPER	mg/L	0.26	Jun-21	1.3

MCL = Maximum Contaminate Level - Enforcable

PFAS = Per- and Polyfluorinated Alkyl Substances

mg/L (ppm) = Milligrams Per Liter (Parts Per Million)

ng/L (ppt) = Nanograms Per Liter (Parts Per Trillion)

APHA = American Public Health Association color scale

***SMCL = Secondary Maximum Contaminate Level - Recommended**

****TT = Treatment Technique**

SOC = Synthetic Organic Chemicals

RAA = Running Annual Average

ACTION LEVEL = Addition treatment required if exceeded

< = Less Than

(FCL) = Fort Collins Lab (UL) = United Lab (SGS) = SGS Lab (MMS) = MMS Environmental (WCL) = Weld County Lab

(CA) = Colorado Analytical Lab (EA) = Eurofins Eaton Analytical (SCFP) = Soldier Canyon Filter Plant

BDL = Below Detectable Limit

HI - Hazard Index

µg/L (ppb) = Micrograms Per Liter (Parts Per Billion)

pCi/L = Picocuries Per Liter

µs/L = MicroSiemens Per Centimeter

ND = Not Detected NT = Not Tested

N/A = Not applicable

VOC = Volatile Organic Chemicals

LRAA = Location Running Annual Average

MRDL = Maximum Residual Disinfectant Level

> = Greater Than