

SOLDIER CANYON WATER TREATMENT AUTHORITY

(East Larimer County Water District; Fort Collins/Loveland Water District; North Weld County Water District)

WATER QUALITY REPORT

3RD QUARTER 2019

ANALYSIS PARAMETER <small>Monitored at SCFP (not a certified lab)</small>	Report	PLANT INFLUENT			PLANT EFFLUENT			MCL *SMCL
	Values	MIN	MAX	AVG	MIN	MAX	AVG	
ALKALINITY	mg/l	9.0	39.0	21.6	30.0	47.0	37.0	N/A
ALUMINUM	mg/l	N/A	N/A	N/A	0.020	0.057	0.040	*0.05 - 0.2
CALCIUM HARDNESS	mg/l	8.0	27.0	19.4	16.0	23.0	19.7	N/A
CHLORINE	mg/l	N/A	N/A	N/A	1.14	1.37	1.26	4.0 MRDL
CHLORITE	mg/l	N/A	N/A	N/A	0.35	0.63	0.50	1.0
CHLORINE DIOXIDE	mg/l	N/A	N/A	N/A	<0.02	<0.02	<0.02	0.8
CONDUCTIVITY	µs/cm	29.9	71.2	56.6	87.6	113.0	100.4	N/A
DISSOLVED OXYGEN	mg/l	4.1	9.4	7.0	N/A	N/A	N/A	N/A
FLUORIDE	mg/l	0.16	0.28	0.23	0.01	0.78	0.42	4.0/*2.0
HARDNESS (TOTAL)	mg/l	14.0	39.0	24.8	23.0	34.0	27.1	N/A
IRON	mg/l	0.05	0.24	0.11	0.00	0.03	0.02	*0.3
LANGLIER INDEX	S.I.#	-1.70	-2.90	-2.22	-0.98	-1.30	-1.13	N/A
MANGANESE	mg/l	0.01	0.17	0.05	0.003	0.008	0.005	*0.05
pH	VALUE	6.83	7.78	7.29	7.93	8.39	8.17	*6.5-8.5
TEMPERATURE	°C	6.9	18.6	11.5	8.5	11.8	10.5	N/A
TOTAL DISSOLVED SOLIDS	mg/l	15.0	35.6	28.2	46.7	56.5	50.8	*500
TRUE COLOR	APHA	2.0	44.0	12.5	0.0	1.0	0.7	*15.0
TURBIDITY	NTU	0.41	7.49	1.70	0.011	0.024	0.013	**<0.3 TT

INORGANIC CONTAMINANTS ANALYSES (AL) - (ENTRY INTO THE DISTRIBUTION SYSTEM)			RESULTS	DATE	MCL
ANTIMONY	mg/l		ND	8/14/2019	0.006
ARSENIC	mg/l		ND	8/14/2019	0.010
BARIUM	mg/l		0.0122	8/14/2019	2.000
BERYLLIUM	mg/l		ND	8/14/2019	0.004
CADMIUM	mg/l		ND	8/14/2019	0.005
CHROMIUM	mg/l		ND	8/14/2019	0.1
FLUORIDE	mg/l		0.62	8/14/2019	4.0
MERCURY	mg/l		ND	8/14/2019	0.002
NICKEL	mg/l		ND	8/14/2019	N/A
SELENIUM	mg/l		ND	8/14/2019	0.050
SODIUM	mg/l		11.4	8/14/2019	N/A
THALLIUM	mg/l		ND	8/14/2019	0.002

NITRATE AND/OR NITRITE AS NITROGEN (AL) - (ENTRY INTO DISTRIBUTION SYSTEM)			RESULTS	DATE	MCL
NITRATE	mg/l		0.068	8/14/2019	10.000
NITRITE	mg/l		<0.04	8/14/2019	1.000

TOTAL ORGANIC CARBON (AL/FCL) - (SCFP INFLUENT AND EFFLUENT)		INFLUENT	EFFLUENT	TT RATIO	DATE	MCL - **TT
TOTAL ORGANIC CARBON - TOC	mg/L	3.20	1.60	1.43	7/10,22/2019	RAA - ≥1.0
		3.20	1.71	1.33	8/14/2019	RAA - ≥1.0
		3.18	1.76	1.28	9/18/2019	RAA - ≥1.0
		INFLUENT			DATE	MCL
ALKALINITY - (SCFP INFLUENT ONLY)	mg/l	24.3			7/10,22,2019	N/A
		24.4			8/14/2019	N/A
		26.2			9/18/2019	N/A

RADIONUCLIDE ANALYSES (UL) - (ENTRY INTO THE DISTRIBUTION SYSTEM)

			RESULTS	DATE	MCL
GROSS ALPHA	pCi/L		1.7	8/24/2011	15
URANIUM	ppb		0.01	8/24/2011	30
RADIUM 226 + 228	pCi/L		0.76	8/24/2011	5
GROSS BETA	pCi/L		2.1	8/24/2011	50

ORGANIC CHEMICAL ANALYSES - VOC's (FCL) - (ENTRY INTO THE DISTRIBUTION SYSTEM)

			RESULTS	DATE	MCL
1,1,1-TRICHLOROETHANE	µg/L		<0.5	8/14/2019	200
1,1,2-TRICHLOROETHANE	µg/L		<0.5	8/14/2019	5
1,1-DICHLOROETHYLENE	µg/L		<0.5	8/14/2019	7
1,2,4-TRICHLOROBENZENE	µg/L		<0.5	8/14/2019	70
1,2-DICHLOROETHANE	µg/L		<0.5	8/14/2019	5
1,2-DICHLOROPROPANE	µg/L		<0.5	8/14/2019	5
BENZENE	µg/L		<0.5	8/14/2019	5
CARBON TETRACHLORIDE	µg/L		<0.5	8/14/2019	5
CHLOROBENZENE	µg/L		<0.5	8/14/2019	100
cis-1,2-DICHLOROETHYLENE	µg/L		<0.5	8/14/2019	70
DICHLOROMETHANE	µg/L		<0.5	8/14/2019	5
ETHYLBENZENE	µg/L		<0.5	8/14/2019	700
o-DICHLOROBENZENE	µg/L		<0.5	8/14/2019	600
para-DICHLOROBENZENE	µg/L		<0.5	8/14/2019	75
STYRENE	µg/L		<0.5	8/14/2019	100
TETRACHLOROETHYLENE	µg/L		<0.5	8/14/2019	5
TOLUENE	µg/L		<0.5	8/14/2019	1000
trans-1,2-DICHLOROETHYLENE	µg/L		<0.5	8/14/2019	100
TRICHLOROETHYLENE	µg/L		<0.5	8/14/2019	5
VINYL CHLORIDE	µg/L		<0.5	8/14/2019	2
XYLENES (total)	µg/L		<0.5	8/14/2019	10000

ORGANIC CHEMICAL ANALYSES - SOC's (AL) - (ENTRY INTO THE DISTRIBUTION SYSTEM)

		RESULTS	DATE	RESULTS	DATE	MCL
1,2-DIBROMO-3-CHLOROPROPANE	µg/L	ND	5/10/2018	ND	8/8/2018	0.2
2,4-D	µg/L	ND	5/10/2018	ND	8/8/2018	70
2,4,5-TP	µg/L	ND	5/10/2018	ND	8/8/2018	50
ALACHLOR (LASSO)	µg/L	ND	5/10/2018	ND	8/8/2018	2
ALDICARB	µg/L	ND	5/10/2018	ND	8/8/2018	N/A
ALDICARB SULFONE	µg/L	ND	5/10/2018	ND	8/8/2018	N/A
ALDICARB SULFOXIDE	µg/L	ND	5/10/2018	ND	8/8/2018	N/A
ATRAZINE	µg/L	ND	5/10/2018	ND	8/8/2018	3
BENZO(a)PYRENE	µg/L	ND	5/10/2018	ND	8/8/2018	0.2
CARBOFURAN	µg/L	ND	5/10/2018	ND	8/8/2018	40
CHLORDANE	µg/L	ND	5/10/2018	ND	8/8/2018	2
DALAPON	µg/L	ND	5/10/2018	ND	8/8/2018	200
DINOSEB	µg/L	ND	5/10/2018	ND	8/8/2018	7
DIQUAT	µg/L	ND	5/10/2018	ND	8/8/2018	20
DI(2-ethylhexyl)ADIPATE	µg/L	ND	5/10/2018	ND	8/8/2018	400
DI(2-ethylhexyl)PHTHALATE	µg/L	ND	5/10/2018	ND	8/8/2018	6
ENDOTHALL	µg/L	ND	5/10/2018	ND	8/8/2018	100
ENDRIN	µg/L	ND	5/10/2018	ND	8/8/2018	2
ETHYLENE DIBROMIDE	µg/L	ND	5/10/2018	ND	8/8/2018	0.05
HEPTACHLOR	µg/L	ND	5/10/2018	ND	8/8/2018	0.4
HEPTACHLOR EPOXIDE	µg/L	ND	5/10/2018	ND	8/8/2018	0.2

ORGANIC CHEMICAL ANALYSES - SOC's (AL) (con't)			RESULTS	DATE	RESULTS	DATE	MCL
HEXACHLOROBENZENE	µg/L		ND	5/10/2018	ND	8/8/2018	1
HEXACHLOROCYCLOPENTADIENE	µg/L		ND	5/10/2018	ND	8/8/2018	50
LINDANE/BHC-GAMMA	µg/L		ND	5/10/2018	ND	8/8/2018	0.2
METHOXYCHLOR	µg/L		ND	5/10/2018	ND	8/8/2018	40
OXAMYL	µg/L		ND	5/10/2018	ND	8/8/2018	200
PENTACHLOROPHENOL	µg/L		ND	5/10/2018	ND	8/8/2018	1
PICLORAM	µg/L		ND	5/10/2018	ND	8/8/2018	500
POLYCHLORINATED BIPHENYLS	µg/L		ND	5/10/2018	ND	8/8/2018	0.5
SIMAZINE	µg/L		ND	5/10/2018	ND	8/8/2018	4
TOXAPHENE	µg/L		ND	5/10/2018	ND	8/8/2018	3

ORGANIC CHEMICAL ANALYSES - SOC's (AL) - (ENTRY INTO THE DISTRIBUTION SYSTEM)

		RESULTS	DATE	RESULTS	DATE	MCL
1,2-DIBROMO-3-CHLOROPROPANE	µg/L	ND	11/7/2018	NT	2/6/2019	0.2
2,4-D	µg/L	ND	11/7/2018	NT	2/6/2019	70
2,4,5-TP	µg/L	ND	11/7/2018	NT	2/6/2019	50
ALACHLOR (LASSO)	µg/L	ND	11/7/2018	NT	2/6/2019	2
ALDICARB	µg/L	ND	11/7/2018	NT	2/6/2019	N/A
ALDICARB SULFONE	µg/L	ND	11/7/2018	NT	2/6/2019	N/A
ALDICARB SULFOXIDE	µg/L	ND	11/7/2018	NT	2/6/2019	N/A
ATRAZINE	µg/L	ND	11/7/2018	NT	2/6/2019	3
BENZO(a)PYRENE	µg/L	NT	11/7/2018	NT	2/6/2019	0.2
CARBOFURAN	µg/L	ND	11/7/2018	NT	2/6/2019	40
CHLORDANE	µg/L	ND	11/7/2018	NT	2/6/2019	2
DALAPON	µg/L	ND	11/7/2018	ND	2/6/2019	200
DINOSEB	µg/L	ND	11/7/2018	NT	2/6/2019	7
DIQUAT	µg/L	ND	11/7/2018	NT	2/6/2019	20
DI(2-ethylhexyl)ADIPATE	µg/L	ND	11/7/2018	NT	2/6/2019	400
DI(2-ethylhexyl)PHTHALATE	µg/L	ND	11/7/2018	ND	5/8/2019	6
ENDOTHALL	µg/L	ND	11/7/2018	NT	2/6/2019	100
ENDRIN	µg/L	ND	11/7/2018	NT	2/6/2019	2
ETHYLENE DIBROMIDE	µg/L	ND	11/7/2018	NT	2/6/2019	0.05
HEPTACHLOR	µg/L	ND	11/7/2018	NT	2/6/2019	0.4
HEPTACHLOR EPOXIDE	µg/L	ND	11/7/2018	NT	2/6/2019	0.2
HEXACHLOROBENZENE	µg/L	ND	11/7/2018	NT	2/6/2019	1
HEXACHLOROCYCLOPENTADIENE	µg/L	ND	11/7/2018	NT	2/6/2019	50
LINDANE/BHC-GAMMA	µg/L	ND	11/7/2018	ND	5/8/2019	0.2
METHOXYCHLOR	µg/L	ND	11/7/2018	NT	2/6/2019	40
OXAMYL	µg/L	ND	11/7/2018	NT	2/6/2019	200
PENTACHLOROPHENOL	µg/L	ND	11/7/2018	NT	2/6/2019	1
PICLORAM	µg/L	ND	11/7/2018	NT	2/6/2019	500
POLYCHLORINATED BIPHENYLS	µg/L	ND	11/7/2018	NT	2/6/2019	0.5
SIMAZINE	µg/L	ND	11/7/2018	NT	2/6/2019	4
TOXAPHENE	µg/L	ND	11/7/2018	NT	2/6/2019	3

DISTRIBUTION SYSTEMS SAMPLES

CHLORINE (Districts Measure)

		TOTAL SAMPLES	MIN	MAX	AVG	DATE	MRDL
EAST LARIMER COUNTY WATER DISTRICT	mg/L	20	0.31	0.96	0.72	Jul-19	4.0
EAST LARIMER COUNTY WATER DISTRICT	mg/L	20	0.72	1.09	0.94	Aug-19	4.0
EAST LARIMER COUNTY WATER DISTRICT	mg/L	20	0.25	1.09	0.87	Sep-19	4.0
FORTCOLLINS/LOVELAND WATER DISTRICT							
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	40	0.45	1.10	0.69	Jul-19	4.0
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	40	0.50	1.20	0.67	Aug-19	4.0
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	40	0.35	1.15	0.72	Sep-19	4.0
NORTH WELD COUNTY WATER DISTRICT							
NORTH WELD COUNTY WATER DISTRICT	mg/L	10	0.26	1.00	0.74	Jul-19	4.0
NORTH WELD COUNTY WATER DISTRICT	mg/L	10	0.33	0.97	0.76	Aug-19	4.0
NORTH WELD COUNTY WATER DISTRICT	mg/L	10	0.31	1.11	0.71	Sep-19	4.0

TOTAL COLIFORMS (MMS/WCL)

		TOTAL SAMPLES	# POSITIVE	# NEGATIVE	DATE	MCL **TT LEVEL 1 or 2
EAST LARIMER COUNTY WATER DISTRICT		20	0	20	Jul-19	NO/NO
EAST LARIMER COUNTY WATER DISTRICT		20	0	20	Aug-19	NO/NO
EAST LARIMER COUNTY WATER DISTRICT		20	0	20	Sep-19	NO/NO
FT COLLINS/LOVELAND WATER DISTRICT						
FT COLLINS/LOVELAND WATER DISTRICT		40	0	40	Jul-19	NO/NO
FT COLLINS/LOVELAND WATER DISTRICT		40	0	40	Aug-19	NO/NO
FT COLLINS/LOVELAND WATER DISTRICT		40	0	40	Sep-19	NO/NO
NORTH WELD COUNTY WATER DISTRICT						
NORTH WELD COUNTY WATER DISTRICT		10	0	10	Jul-19	NO/NO
NORTH WELD COUNTY WATER DISTRICT		10	0	10	Aug-19	NO/NO
NORTH WELD COUNTY WATER DISTRICT		10	0	10	Sep-19	NO/NO

TOTAL TRIHALOMETHANES AND HALOACETIC ACIDS

		TTHM RESULTS	MCL (LRAA)	HAA RESULTS	MCL (LRAA)	DATE
EAST LARIMER COUNTY WATER DISTRICT (AL)						
SAMPLE SITE - DBP001	µg/L	42.1	80	29.1	60	7/23/2019
SAMPLE SITE - DBP002	µg/L	45.2	80	28.0	60	7/23/2019
SAMPLE SITE - DBP003	µg/L	33.7	80	28.0	60	7/23/2019
SAMPLE SITE - DBP004	µg/L	46.6	80	22.1	60	7/23/2019
FORT COLLINS/LOVELAND WATER DISTRICT (CA)						
SAMPLE SITE - DBP001	µg/L	23.5	80	23.6	60	7/2/2019
SAMPLE SITE - DBP002	µg/L	37.7	80	30.2	60	7/2/2019
SAMPLE SITE - DBP003	µg/L	28.7	80	25.7	60	7/2/2019
SAMPLE SITE - DBP004	µg/L	41.9	80	26.7	60	7/2/2019

Total Trihalomethanes and Haloacetic Acids (cont)

		TTHM RESULTS	MCL (LRAA)	HAA RESULTS	MCL (LRAA)	DATE
NORTH WELD COUNTY WATER DISTRICT (WCL)						
SAMPLE SITE - DBP001	µg/L	45.9	80	24.70	60	7/9/2019
SAMPLE SITE - DBP002	µg/L	36.2	80	30.70	60	7/9/2019
SAMPLE SITE - DBP003	µg/L	42.1	80	35.00	60	7/9/2019
SAMPLE SITE - DBP004	µg/L	34.0	80	30.00	60	7/9/2019

CHLORITE

		1ST RES	AVG RES	MAX RES	DATE	MCL
EAST LARIMER COUNTY WD (FCL)	mg/L	0.43	0.44	0.47	7/16/2019	1.0
FORT COLLINS/LOVELAND WD (EA)	mg/L	0.60	0.58	0.35	7/2/2019	1.0
NORTH WELD COUNTY WD (WCL)	mg/L	0.52	0.52	0.50	8/1/2019	1.0

LEAD AND COPPER

EAST LARIMER COUNTY WATER DISTRICT (AL)

		90TH PERCENTILE mg/L	DATE	90th% ACTION LEVEL mg/L
		30 SAMPLES COLLECTED		
LEAD	mg/L	0.0035	JUN-SEP 2019	0.015
COPPER	mg/L	0.2	JUN-SEP 2019	1.3

FORT COLLINS LOVELAND WATER DISTRICT (CA)

		30 SAMPLES COLLECTED	DATE	90th% ACTION LEVEL mg/L
LEAD	mg/L	0.003	Jun-19	0.015
COPPER	mg/L	0.296	Jun-19	1.3

NORTH WELD COUNTY WATER DISTRICT (AL)

		30 SAMPLES COLLECTED	DATE	90th% ACTION LEVEL mg/L
LEAD	mg/L	0.0038	Jul-19	0.015
COPPER	mg/L	0.26	Jul-19	1.3

MCL = Maximum Contaminate Level - Enforcable

*SMCL = Secondary Maximum Contaminate Level - Recomendend

**TT = Treatment Technique

SOC = Synthetic Organic Chemicals

RAA = Running Annual Average

ACTION LEVEL = Addition treatment required if exceeded

< = Less Than

(FCL) = Fort Collins Lab (UL) = United Lab (AL) = Accutest Lab (MMS) = MMS Environmental (WCL) = Weld County Lab

(CA) = Colorado Analytical Lab (EA) = Eurofins Eaton Analytical (SCFP) = Soldier Canyon Filter Plant

BDL = Below Detectable Limit

ND = Not Detected

N/A = Not applicable

VOC = Volatile Organic Chemicals

LRAA = Location Running Annual Average

MRDL = Maximum Residual Disinfectant Level

> = Greater Than